



सरकारी गजट, उत्तर प्रदेश

उत्तर प्रदेशीय सरकार द्वारा प्रकाशित

असाधारण

विधायी परिशिष्ट

भाग-4, खण्ड (ख)

(परिनियत आदेश)

लखनऊ, सोमवार, 29 जनवरी, 2024

माघ 9, 1945 शक सम्वत्

उत्तर प्रदेश शासन

ऊर्जा अनुभाग-3

संख्या 73/चौबीस-पी-3-2024-3245-2022

लखनऊ, 29 जनवरी, 2024

अधिसूचना

प0आ0-34

चूँकि उत्तर प्रदेश सौर ऊर्जा नीति, 2022 के प्रस्तर 7.3 (ई) में यह उपबन्ध किया गया है कि 10 किलोवाट तक के ग्रिड संयोजित रूफटॉप सोलर पावर प्लाण्ट की स्थापना और परीक्षण को विद्युत निरीक्षक द्वारा निरीक्षण से छूट दी जायेगी।

2-अतएव, अब, विद्युत अधिनियम, 2003 (अधिनियम सं० 36 सन् 2003) की धारा 162 की उपधारा (1) तथा केन्द्रीय विद्युत प्राधिकरण (सुरक्षा तथा विद्युत आपूर्ति सम्बन्धी उपाय) विनियम, 2010 के विनियम 32 के अधीन शक्तियों का प्रयोग करके राज्यपाल, यह निर्देश देती हैं कि 10 किलोवाट तक के ग्रिड संयोजित रूफटॉप सोलर पावर प्लाण्ट की स्थापना और परीक्षण को विद्युत निरीक्षक द्वारा निरीक्षण से छूट दी जायेगी।

आज्ञा से,
महेश कुमार गुप्ता,
अपर मुख्य सचिव।

IN pursuance of the provisions of clause (3) of Article 348 of the Constitution, the Governor is pleased to order the publication of the following English translation of Government notification no. 73/XXIV-P-3-2024-3245-2022, dated January 29, 2024.

No. 73/XXIV-P-3-2024-3245-2022

Dated Lucknow, January 29, 2024

WHEREAS in paragraph 7.3 (e) of the Uttar Pradesh Solar Energy Policy, 2022 it has been provided that installation and testing of grid connected roof top Solar Power Plants upto 10 KW shall be exempted from inspection by Electrical inspector;

NOW, THEREFORE, in exercise of the powers under sub-section (1) of section 162 of the Electricity Act, 2003 (Act no. 36 of 2003) and regulation 32 of Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2010, the Governor is pleased to direct that the installation and testing of grid connected roof top Solar Power Plants upto 10 KW shall be exempted from inspection by Electrical inspector.

By order,

MAHESH KUMAR GUPTA,

Apar Mukhya Sachiv.

पी0एस0यू0पी0-ए0पी0 1108 राजपत्र-2024-(3097)-599 प्रतियाँ (कम्प्यूटर/टी0/ऑफसेट)।
पी0एस0यू0पी0-ए0पी0 12 सा0 ऊर्जा-2024-(3098)-500 प्रतियाँ (कम्प्यूटर/टी0/ऑफसेट)।